

EUROFLAT SERIES TYPES CM11/O CM31/O CE11/O CE31/O

AUTOMATIC GAS BURNER CONTROL SYSTEMS FOR GAS BURNERS AND GAS BURNING APPLIANCES WITH OR WITHOUT FAN



Application

This range of electronic gas burner control systems has been designed specifically for atmospheric and fan assisted burners for intermittent operation (systems for non-permanent operation).

The control units CM11/O and CM31/O are provided with **non-volatile** lock-out, which means that a restart from the safety shut-down condition can only be accomplished by a manual reset of the system.

The control units CE11/O and CE31/O are provided with **volatile** lock-out which means that a restart from the safety shut-down condition can only be accomplished by an interruption of the main power and its subsequent restoration.

The control units of this series are suitable for the connection with high level electronic control boards, with insulation between the automatic ignition system and the control part at low voltage. In fact the controls which carry out the correct operation of the ignition burner cycle and flame monitoring are suitable to transmit the necessary signals for the control part operation using three optoisolators with insulation of 4KV and clearance and creepage distances of the printed circuit board \geq 8mm (reinforced isolation).

These automatic burner control units are therefore fit to be connected to SELV circuits (Safety Extra Low Voltage, e.g. 24V). The signals transmitted by means of the

optoisolators are:

- flame detection
- lock-out
- reset

The automatic burner control units of this series are suitable for:

-combi boilers

-heating boilers

-warm air generators

-radiant heaters

-water heaters

Due to the design and the variety of models they can be used also for the automation of ovens, cookers and in general in gas firing installations with atmospheric burner.

Features

Table 1 shows the main features of this series. Other important features are:

- EC Type certification (CE Reg. N° 63AQ0625) in accordance with Gas Appliance Directives 90/396 and 93/68;
- in accordance with EN298 (European standard for automatic gas burner control systems);
- flame monitoring by the rectification property of the flame: ionization;
- electrical service life at max. loading >250.000 operations;
- inbuilt ignition device completely of solid state design and high efficiency;

TABLE 1	BURNER		OPTIONS				
	single flame	atmospheric without fan	atmospheric with fan	non-volatile lock-out	volatile lock-out	classification code	according to EN298 (1)
CM 11/O	*	*		*		AMC	LXN
CM 31/O	*		*	*		FMCLXN	
CE11/0	*	*			*	AMCVXN	
CE 31/ O	*		*		*	FMC∖	/XN

1) Flame failure during TS causes spark restoration

TECHNICAL DATA

Supply Voltage:	230V~ 50/60Hz
on request:	110/120V~ 50/60Hz
Operating temperature range:	-20℃ +60℃
Ambient humidity:	95% max at 40℃
Protection degree:	IP 00
Times:	
-Prepurge or waiting time (TW):	1,5/3/5/10/20/30/40 s

-Safety time (**TS**): 3/5/8/10/20/30/40/50/60 s -Drop out time on running flame failure: < 1 s The times given on the burner control label correspond to the values guaranteed. The actual values differ slightl from the values given, pre-purge and waiting times are in fact longer and safety time shorter than their nominal values. **Power consumption, at starting up**:

atmospheric burner 10 VA 12 VA atmospheric fan-assisted burner Power consumption, running: 7 VA atmospheric burner atmospheric fan-assisted burner 9 VA Contact rating: I max -Thermostat: 4 A $\cos \phi = 0.4$ -VG1: $0.5 \text{ A} \cos \phi = 0.4$ -Fan 1 A $\cos \phi = 0.4$ Max. length of the cables of external components: 1 m Fuse rating internal: 4 A Fast 3.15 A Fast Fuse rating external: Flame control:

The ionization flame detector device makes use of the rectification property of the flame.

The ionization flame detector device is not a safe to touch output (no provision with protective impedances).

-Minimum ionization	on current:	1.2µA			
C	on request:	0.5μΑ			
-Recommended	ionization	current:3 ÷ 5	times	the	
minimum					
ionization current					
-Max length of the	cable:	1 m			
-Minimum insulation	on resistanc	e of cable and	flame		
detector device to	earth:	\geq 50M Ω			
-Max. parasitic ca	pacitance of	f			
detection probe:		≤1nF			
-Max. short circuit	current:	< 200μA .	< 200µA AC		
Ignition:					
-Ignition voltage:		20 KV at 30pF loading			

-Repetition rate:	25 Hz
-Max.length of the cable:	2 m
-Spark gap recommended:	2-4 mm
-Consumption:	2,5 VA
-Spark energy:	15 mJ
Optoisolators (current rating):	
- flame detection:	$5\text{mA}\pm20\%$
- lock-out signal:	$5mA \pm 20\%$
- reset:	$50 \text{mA} \pm 20\%$
Weight:	200 g

Controls for special applications:

On request it is possible to meet special requirements concerning times, repetition rate of the sparks, minimum ionization current and operating cycle.

CONSTRUCTION

The enclosure made of plastic material protects the control from mechanical damage, dust and dirt from the conditions of installation.

The printed circuit board dimensions have been reduced by means of a module with surface mounted components.

A varistor protects the control from voltage transients on the mains supply. An internal fuse protects the relays of the control box in case of short circuits on the outputs (valve and fan). This is not an accessible fuse and the control must be protected with a fuse of the fast blow type suitable to the load connected and never exceeding 3.15A.

Overall Dimensions

The following figure (Fig. 1) shows the overall dimensions of the controls.



Accessories

The control units are usually supplied with a kit of female connectors. Do no fit terminals and female connectors of different types.

These accessories can be supplied upon request (see Fig.2).



FEMALE CONNECTORS STOCKO: MKF 2800 STELVIO:BS95/... TERMINALS STOCKO: RFB 7851 STELVIO: CT84

Connection

Using non reversible connectors with different number of poles makes the connection easy and reliable. One way fast-on connectors of different sizes for ignition and detection electrodes permit their easy installation and replacement.

The dual output ignition device allows spark generation on one point (a), two points (b) or between two electrodes isolated from the metal frame of the burner (c), see Fig.3.



Regarding the connection of the control units, provisions such as strain reliefs, sufficient earth terminals and neutral terminals should be present in the appliance or in external connection boxes.

DIRECTIONS FOR THE USE

- For technical-safety reasons a regulation shutdown must occur every 24 hours (systems for nonpermanent operation).
- Automatic controls are safety devices and shall not be opened. Responsibility and guarantee of the manufacturer is invalidated if the control is opened.
- The control must be connected and disconnected only without the main power.
- The control can be mounted in any position.
- Avoid exposure of the control unit to dripping water.
- Ventilation and the lowest temperature ensures the longest life of the control.
- Make sure that the type (code and times) you are using is correct before installing or replacing the control.
- The gas appliance in which the control is installed must provide adequate protection against the risk of electrical shock (at least IP20).

Electrical installation

- The applicable national regulation and European standards (e.g. EN60335-1/prEN50165) regarding electrical safety must be respected.
- Live and neutral should be connected correctly, a mistake could cause a dangerous situation, i.e. the valve would still be live with the thermostats and limits switched off. Besides, if live-neutral polarity is not respected the control performs a non-volatile or volatile lock-out at the end of the safety time at starting up.
- Before starting check the cables carefully. Wrong connections can damage the control and compromise the safety.
- The earth terminal of the control, the metal frame of the burner and the earth on the mains supply must be well connected.
- Avoid putting the detection cable and SELV signals close to power or ignition cables.

- Use a heat resistant cable for the detection probe, well insulated to ground and protected from possible moisture (or water in general).
- Use an ignition cable as short and straight as possible and keep it far from other conductors to reduce the emission of electromagnetic interference (max.length <2m and insulation voltage >25KV).

In case of live-neutral network with unearthed neutral or live-live network (with centre of the star not earthed) the control can operate correctly by means of a built-in resistor. IMPORTANT: in the event of "partial" short circuits or bad insulation between phase(s) and earth the voltage on the ionization probe can be reduced until it causes the lock-out of the control. In the presence of this kind of network it is advisable to use our isolation transformer type AR1.

Checking at start

Always check the control before the first start and also after substitutions or a long period of non operation of the system. Before any ignition attempt make sure that the combustion chamber is free from gas.

Then make sure that:

- if the attempt to start occurs without the gas supply the control performs a non-volatile or volatile lock-out after TS;
- when stopping the gas flow (while the control is in running state) supply to the gas valve is interrupted within 1 second and after a recycling, the control proceeds to a non-volatile or volatile lock-out;
- operating times and sequence are suitable;
- the level of the flame signal is sufficient, see Fig.4 for the measuring test;
- the ignition probe(s) is (are) adjusted in the most stable way for a spark gap between 2-4 mm;
- the intervention of limiters or safety devices causes a safety shut-down according to the application.



Operation

At every start the control unit proceeds to a self-checking of its own components. During the pre-purge or waiting time the internal circuit makes a test of the flame signal amplifier circuit. A parasitic flame signal or fault in the amplifier prevents the control from starting.

In the types with control of the fan, before the elapsing of pre-purge time, the air pressure switch contacts are checked to prove their "no air flow" state.

Only if the test is positive the fan is started and with the air pressure switch in "air flow" state, pre-purge time begins.

At the end of the waiting or pre-purge times the gas valve is energized and the ignition device is operated. If a flame is detected during the safety time the ignition device is inhibited and the flame detection optoisolator switches from off to flame detected condition. On the contrary, if the control doesn't detect a flame by the end of TS, it proceeds to non-volatile or volatile lock-out, the gas valve and the ignition device are switched off while the lock-out signal optoisolator switches.

When the flame fails during the safety time, then the ignition device is activated within one second.

The attached diagrams are useful to understand how each control operates.

In Fig.5 there is an example of connection between a CM11/O control and a control device. For further information about the correct apllication of these controls please contact our technical department.

Reset of the control

When a control has gone to non-volatile or volatile lockout, an interval of 10 seconds should be allowed before attempting to reset the control unit; if this time is not observed then the control may not reset correctly. In case of volatile lockout, the restart from the safety shutdown condition can only be accomplished by an interruption of the main power and it subsequent restoration.

The volatile lock-out models do not contain an independent manual reset function. The application of these types of controls is therefore restricted to only those appliances where resetting by switching off the heat demand is allowed by European standards.

In general, resetting of the appliance must occur in sight and in the near vicinity of the appliance. Resetting must also occur by means of a conscious manual action and not by means of automatic device like thermostats or timers.

Please note that it is allowed to combine the reset button together with the main switch on the appliance. In this case the alarm light will have to be installed too.



Fig.5

CONNECTION DIAGRAMS



NOTE: the limit thermostat has to be wired in series to the live.

OPERATING CYCLES



ATTENTION -> Company Brahma S.p.A. takes no responsibility for any damage resulting from Customer's tampering with the device.

BRAHMA S.p.A. Via del Pontiere, 31 37045 Legnago (VR) – ITALY Tel. +39 0442 635211 – Fax +39 0442 25683 http://www.brahma.it E-mail: brahma@brahma.it

2011/06/07 subject to amendments without notice